

RWH-151


General Protection Device

Wide applicability

High reliability

Easy to install and maintain

Integration of multiple protection functions



Comply with IEC / CEI /GB/JB/DL standards

Provided customized manufacture

Whole solutions for design, assembly, test...

Accountable solution for safety and reliability

Wide range offering, easy business and convenient installation

Version 2025 Copyright RW Energy

Foreword

Please read this chapter carefully before using this product!

This chapter introduces the safety precautions before using this product. Please make sure the content of this chapter is fully read and understood before installation and usage. Our company will not undertake any responsibilities for any damage or injury caused by improper operations because of ignoring relevant warning in this operation instruction.

Before operating this device, relevant professional personnel shall read this instruction carefully and well understand the content.

Operation instructions and warnings:

The following standard definitions will be adopted in this operation instruction.

Danger! Ignoring of safety precautions may cause personal death, serious personal injury or serious equipment damage.

Warning! Ignoring of safety precautions may cause personal death, serious personal injury or serious equipment damage.

Caution! Ignoring of safety precautions may cause a slight personal injury or equipment damage, especially the damage of device or the equipment protected by the device.

- **Danger!**

When the primary system is live working, secondary open circuit for the current transformer connected to the device is absolutely forbidden, and the open of this circuit may cause extremely dangerous high voltage.

- **Warning!**

Some parts of the device may have high voltage when the electrical device is running. Improper operation may cause serious personal injury or equipment damage.

Only qualified professional personnel are allowed to operate the device or work nearby the device. The operators professional shall well understand the precautions, working flows and safety regulations mentioned in this instruction.

- **Caution!**

Grounding terminals of the device shall be firmly grounded.

The device is only permitted to run in atmospheric environment that specified in the technical specifications, and abnormal vibrations shall be avoided in its running environment.

When connect the AC voltage current circuit or power circuit, please make sure they conform to the rated parameters of the device.

When the output terminals of the device are connected to external circuit, please check carefully the voltage of external power to prevent overheating of the circuit.

Carefully check the cable connected to the device, preventing applying too much external force on it.

Contents

CHAPTER 1: OVERVIEW	5
1.1 Description	5
1.2 Protection	5
1.3 Supervision	5
1.4 Control.....	5
1.5 Features	6
1.6 Monitoring Functions	6
1.7 Hardware	6
1.8 Data Storage and Communication	7
1.9 RF remote controller	7
CHAPTER 2: TECHNICAL PERFORMANCE INDEX	8
2.1 Inputs and Outputs	8
2.2 Unit Design	9
2.3 Serial Interface	10
2.4 Data Storage	10
2.5 Mechanical Tests	10
2.6 Electrical Tests	11
2.7 Climatic Tests	12
CHAPTER 3: PROTECTION FUNCTIONALITY	13
3.1 Function Description	13
3.2 Constant Value Parameters	17
CHAPTER 4: USER INTERFACE	19
4.1 LEDs	19
4.2 Keypad	20
4.3 LCD	22
4.4 The Main Menu	22

4.5 Submenu	23
4.6 Entering the password interface	25
4.7 Relay setting	25
4.8 Save parameter	30
4.9 Parameter set	31
4.10 Calibration	34
4.11 Clear report	34
4.12 Factory setting	34
4.13 View primacy meter	34
4.14 View SOE	35
4.15 View relay and setting	36
4.16 View input signal	36
4.17 View version information	36
CHAPTER 5: INSTALLATION AND MAINTENANCE	37
CHAPTER 6: DECOMMISSION AND DISPOSAL	38
6.1 Decommission	38
6.2 Disposal	38
ATTACHMENT1: DEVICE TERMINAL DIAGRAM	39
ATTACHMENT2: DEVICE TYPICAL WIRING DIAGRAM (LINE MODE)	40

Chapter 1: Overview

1.1 Description

General Protection Device is a microprocessor as the core, combined with modern electronic technology, computer technology, communication technology, to realize the power system fault detection, protection control and operation monitoring function of intelligent equipment. As the key line of defense for the safe and stable operation of the power system, it replaces the traditional electromagnetic protection device and significantly improves the reliability, sensitivity and speed of protection.

The device is mainly composed of data acquisition system, microprocessor unit, input/output interface, communication module and power module. When working, the data acquisition system collects analog signals such as current and voltage in real time, and transmits them to the microprocessor after analog-to-digital conversion; the microprocessor analyzes and calculates the data according to preset protection algorithms and logic programs, and determines whether a fault or abnormality occurs in the power system; once a fault is detected, it quickly drives the circuit breaker to trip and removes the faulty equipment through the output interface and uploads the fault information to the monitoring center through the communication module. Upload the fault information to the monitoring center through the communication module.

Support communication protocols: IEC 60870-5-101 IEC 60870-5-104 Modbus DNP3.01.2 Protection.

1.2 Protection.

49	Thermal Overload (Over load)
50	Instantaneous Overcurrent (Ph.OC)
50G/N/SEF	Instantaneous Sensitive Earth Fault (SEF)
27/59	Under/Over Voltage (Ph.OV/Ph.UV)
51c	Cold load pickup (Cold load)

1.3 Supervision

60CTS	CT Supervision
60VTS	VT Supervision

1.4 Control

79	Auto Reclose
86	Lockout
	CB Control

1.5 Features

Password Protection – 2 levels.

50Hz systems and two phase/three phase wiring method are available, so that the use scope of device is extended.

Protection configuration is complete, and all protection functions can be switched on and off flexibly.

4-way intellectual switching value input.

Large capacity flash memory can record at least 100 times of historical events, and no data will loss even the power is off.

Circuits operating loop can be used both the direct or alternating current, self-adaptation open/close brake function, which can co-work with various of breakers, and the operation is simple and reliable.

The device has complete self-inspection function to in-service monitor the working conditions of various parts of the device, ensuring the reliability of the device.

1.6 Monitoring Functions

Primary Currents Phases and Earth Direction

Secondary PT Voltage

Frequency

Binary Input/Output status

Trip circuit healthy/failure

Time and date

Fault records

Event records

1.7 Hardware

4CT 1 VT 7 Binary Inputs 2 Binary Outputs

4CT 2 VT 7 Binary Inputs 2 Binary Outputs

1.8 Data Storage and Communication

RS485, RS232, RJ45 port

Protocols –IEC60870-5-101, IEC60870-5-104, DNP3.0 or Modbus RTU

Event Records

Fault Records


Measurands

Commands

Time Synchronism

Viewing and Changing Settings

1.9 RF remote controller

	<p>Function of each key</p> <p>A:Close</p> <p>B:Trip</p> <p>C:Unlock</p> <p>D:Reset</p>
--	---

Note:

1. In order to prevent misuse, press the unlock button for 3 seconds, before execution of the closing operation.
2. The effective distance of RF remote controller is 30 meters.

Chapter 2: Technical Performance Index

2.1 Inputs and Outputs

Phase Current Inputs

Quantity	3
Rated Current In	5A
Measuring Range	20 x In
Instrumentation $\geq 0.1 \times \text{In}$	$\pm 1\% \text{ In}$
Frequency	50Hz
Thermal Withstand:	
Continuous	2 x In
10 Second	10 x In
1 Second	40 x In
Burden @ In	$\leq 0.2\text{VA}$ (5A Phase element)

Sensitive Earth Current Inputs

Quantity	1
Rated Current In	5A
Measuring Range	2 x In
Instrumentation $\geq 0.1 \times \text{In}$	$\pm 1\% \text{ In}$
Frequency	50/60Hz
Thermal Withstand:	
Continuous	2 x In
10 Second	10 x In
1 Second	40 x In
Burden @ In	$\leq 0.02\text{VA}$ (1A Earth element)

Voltage Inputs

Quantity	1 PT voltage
Nominal	40...120 Vrms
Operating Range	0...200 Vrms
Instrumentation $\geq 0.8 \times V_n$	$\pm 1\% V_n$
Burden @ 110V	0.06 VA
Overvoltage Withstand	240 Vrms

Auxiliary Supply

DC Voltage	220V Range 165 to 365V
AC Voltage	220 V AC 50Hz Range 165 to 265Vrms AC 50/60Hz $\pm 5\%$
Power consumption	$\leq 10W$

Binary Inputs

Number	7
Operating Voltage	24V DC
Maximum dc current for operation	2mA

Binary Outputs

Number	2
Operating Voltage	220V DC
Operating Mode	User selectable - Self or Hand/Electrical Reset or pulsed
Operating Time from Energizing Binary Input	<20ms

2.2 Unit Design

Indication	16 Character 4 line Display 10 LED's
User Interface	11 Navigation Keys
Weight	18kg

2.3 Serial Interface

Communication Port	RS485, RS232, RJ45
Protocols	IEC60870-5-101 IEC60870-5-104 DNP3.0 MODBUS RTU

2.4 Data Storage

Events	100 times
--------	-----------

2.5 Mechanical Tests

Vibration (Sinusoidal) --- IEC 60255-21-1 Class I

Type	Level	Variation
Vibration response	0.5gn	≤5%
Vibration withstand	1.0gn	≤5%

Shock and Bump --- IEC 60255-21-2 Class I

Type	Level	Variation
Shock response	0.5gn, 11ms	≤5%
Shock withstand	15gn, 11ms	≤5%
Bump test	10gn, 16ms	≤5%

Shock and Bump --- IEC 60255-21-3 Class I

Type	Level	Variation
Seismic response	X-plane-3.5mm Displacement below crossover freq (8-9Hz) 1gn and above Y-plane-1.5mm Displacement below crossover freq (8-9Hz) 0.5gn above	≤5%

Mechanical Classification

Durability	>106 operations
------------	-----------------

2.6 Electrical Tests

Insulation --- IEC 60255-5

Type	Level
Between any terminal and earth	2.0 kV AC RMS for 1 min
Between independent circuits	2.0 kV AC RMS for 1 min
Across normally open contacts	kV AC RMS for 1 min

High Frequency Disturbance --- IEC 60255-22-1 Class III

Type	Level	Variation
Common (longitudinal) mode	2.5 kV	≤5%
Series (transverse) mode	1.0 kV	≤5%

High Frequency Disturbance --- IEC 60255-22-2 Class IV

Type	Level	Variation
Contact discharge	8.0 kV	≤5%

Fast Transients --- IEC 60255-22-4 Class A (2002)

Type	Level	Variation
5/50 ns 2.5 kHz repetitive	4 kV	≤5%

Surge Immunity --- IEC 60255-22-5

Type	Level	Variation
Analog Inputs: Line to Earth	4.0 kV	≤10%
Case, Aux Power & I/O: Line to Earth	2.0 kV	≤10%
RS485 Comms port: Line to Earth	1.0 kV	No Data Loss
Analog Inputs: Line to Line	1.0 kV	≤10%
Case, Aux Power & I/O: Line to Line	1.0 kV*	≤10%

* Note 45ms DTL pick-up delay applied to binary inputs

Conducted Radio Frequency Interference --- IEC 60255-22-6

Type	Level	Variation
0.15 to 80 MHz	10 V	≤5%

Radiated Radio Frequency --- IEC 60255-25

Type	Limits at 10 m, Quasi-peak
30 to 230 MHz	40 dB(μV)
230 to 10000 MHz	47 dB(μV)

Conducted Radio Frequency

Type	Limits	
	Quasi-peak	Average
0.15 to 0.5 MHz	79 dB(μV)	66 dB(μV)
0.5 to 30 MHz	73 dB(μV)	60 dB(μV)

Radiated Immunity --- IEC 60255-22-3 Class III

Type	Level
80 MHz to 1000 MHz Sweep	10 V/m
1.4GHz to 2.7GHz Sweep	10 V/m
80,160,380,450,900,1850,2150 MHz Spot	10 V/m

2.7 Climatic Tests**Temperature --- IEC 60068-2-1/2**

Operating Range	-55°C to +70°
-----------------	---------------

Humidity --- IEC 60068-2-78

Operational test	56 days at 40°C and 93% relative humidity
------------------	--


Chapter 3: Protection Functionality

3.1 Function Description

Under Voltage (Ph.UV)

PT voltage is used as the criterion of undervoltage protection. There are two sections of undervoltage protection here.

Action Logic diagram:




Note: Run is "√", Stop is "×".

UAB—Secondary PT voltage Uset—Pickup voltage T—Delay time

Power on

The device will control the CB to close when the PT voltage greater than pickup voltage.

Action Logic diagram:




Note: Run is "√", Stop is "×".

UAB—Secondary PT voltage Uset—Pickup voltage T—Delay time

Over Voltage (Ph.OV)

PT voltage is used as the criterion of over-voltage protection. There are two sections of overvoltage protection here.

Action Logic diagram:




Note: Run is "√", Stop is "×".

UAB—Secondary PT voltage Uset—Pickup voltage T—Delay time

51c Cold Load Pickup (Cold Load)

If a circuit breaker is closed onto a "cold" load, i.e. one that has not been powered for a prolonged period, this can impose a higher than normal load-current demand on the system which could exceed normal settings. These conditions can exist for an extended period and must not be interpreted as a fault. To allow optimum setting levels to be applied for normal operation, the cold load pickup feature will apply alternative current settings for a limited period. The feature resets when either the circuit breaker has been closed for a settable period, or if the current has reduced beneath a set level for a user set period.

Action Logic diagram:



Note: Run is "✓", Stop is "✗".

IA IB IC—Measured current

I'set—Cold load pickup current


Iset—Ph.OC pickup current

T—Delay time

50P Phase Fault (Ph.OC)

Three sections phase overcurrent protection for lines include Ph.OC1 (instantaneous overcurrent protection), Ph.OC2 (definite time overcurrent protection) and Ph.OC3 (overcurrent protection). All of which are definite time actuate features.

Action Logic diagram:



Note: Run is "✓", Stop is "✗".

IA IB IC—Measured current

Iset—Pickup current

T—Delay time

50G/50N Sensitive Earth Fault (SEF)


When the switch is set at the end of the line, the zero sequence current can be used to protect the earth fault when the capacitance of the power supply side to the earth is large and the capacitance of the load side to the earth is small.

When the switch is set at the end of the line, the ground fault on the load side of the switch can be detected only according to the zero sequence current. However, if there is a large capacitance to ground on the load side, it is possible to detect the zero sequence current and misoperate when there is a ground fault on the power side. Therefore, it is necessary to judge the direction and fault point of the grounding current according to the amplitude of the zero sequence current and the phase angle between the zero sequence voltage and the current, in order to prevent this unnecessary misoperation.

The angle between zero sequence directionality refers to the angle between zero sequence voltage and zero sequence current and the angle of zero sequence current leading to zero sequence voltage. When conducting zero sequence directionality test, the starting angle and ending angle of zero sequence action interval can be modified. After being put into operation, the zero sequence current in the section shall exceed the set value, and the zero sequence directional protection can only operate, otherwise it will not operate.

For example, the start angle of zero sequence action section is set to 240° and the end angle of zero sequence action section is set to 300° . At this time, enter the "VIEW" → "Meter" menu to check the angle of IU0an (IU0an is the angle of zero sequence current ahead of zero sequence voltage). Only when it is between $240^\circ \sim 300^\circ$ and the zero sequence current exceeds the set value, the zero sequence directional overcurrent will act, otherwise it will not act.

Action Logic diagram:



Note: Run is "√", Stop is "×".

3I0—SEF current

I0set—Pickup current

T—Delay time

θ1—Start angle

θ2—End angle

IU0an—Angle of zero sequence current ahead of zero sequence voltage


Note: If zero sequence directional overcurrent protection is required, it shall be specified when ordering. The normal delivery is zero sequence overcurrent without direction.

79 Auto - Reclose (Reclose)

A high proportion of faults on an overhead line network are transient and can be cleared quickly by high speed tripping followed by an automated circuit breaker reclose sequence.

The function provides phase fault and earth fault/sensitive earth fault sequences of up to 5 trip i.e. 4 reclose attempts before lockout, and the charging period of the reclose is 10 seconds.

Action Logic diagram:




Note: Run is "√", Stop is "×".

Reclosing acceleration (Recl.ACC)

When switching on reclosing acceleration, if accidents happened in 3S after the reclose is operated, the phase over current protection will accelerate the operation.

Action Logic diagram:




Note: Run is "√", Stop is "×".

IA IB IC—Measured current Iset—Pickup current T—Delay time

Manual closing acceleration (Manu.ACC)

When switching on manual closing acceleration, if accidents happened in the exit time after operated the close, the phase over current protection will accelerate the operation. The exit time of acceleration can be adjusted.

Action Logic diagram:




Note: Run is "√", Stop is "×".

IA IB IC—Measured current Iset—Pickup current T—Delay time

Prepaid (Optional features)

It is used to connect the dosing tank, the device will control the CB to trip when the dosing tank is in deficit.

Action Logic diagram:



Note: Run is "√", Stop is "×".

3.2 Constant Value Parameters

All values are given primary side.

Under Voltage (Ph.UV)

Description		Setting range	Step length
PH.UV	Operating mode	1. Trip 2. Alarm	
	Pickup voltage	0.01~42KV	0.01KV
	Delay time	0~99.99S	0.01S

Power on

Description		Setting range	Step length
Power on	Pickup voltage	0.01~42KV	0.01KV
	Delay time	0~99.99S	0.01S

Over Voltage (Ph.OV)

Description		Setting range	Step length
PH.OV	Pickup voltage	0.01~42KV	0.01KV
	Delay time	0~99.99S	0.01S

51C Cold Load Pickup (Cold load)

Description		Setting range	Step length
Cold load	Pickup current	1~6000A	0.1A
	Delay time	0~99.99S	0.01S

50P Phase Fault (Ph.OC)

Description		Setting range	Step length
PH.OC1	Pickup current	0.1~6000A	0.1A
	Delay time	0~9.99S	0.01S
PH.OC2	Pickup current	0.1~6000A	0.1A
	Delay time	0~9.99S	0.01S
PH.OC3	Pickup current	0.1~6000A	0.1A
	Delay time	0~99.99S	0.01S

50G/N Sensitive Earth Fault (SEF)

Description		Setting range	Step length
SEF	Operating mode	1.Alarm 2.Trip	
	Pickup current	0.1~999.9A	0.1A

	Delay time	0~600S/M	0.1S/M
	Start angle	0~360°	1°
	End angle	0~360°	1°

79 Auto - Reclose (Reclose)

Description		Setting range	Step length
Reclose	Reclose count	1:One 2:Two 3:Three 4:Four	
	Delay time	0~99.99S	0.01S
	Reset time	1.2~180S	0.1S

Reclosing acceleration (Recl.ACC)

Description		Setting range	Step length
Recl.ACC	Pickup current	0.1~6000A	0.1A
	Delay time	0~9.99S	0.01S


Manual closing acceleration (Manu.ACC)

Description		Setting range	Step length
Manu.ACC	Exit time	0.1~9.99S	0.01S
	Pickup current	0.1~6000A	0.1A
	Delay time	0~9.99S	0.01S

Prepaid (Optional features)


Description		Setting range	Step length
Prepaid	Delay time	0~99.99S	0.01S

Chapter 4: User Interface



The operator interface is designed to provide a user friendly method of controlling, viewing menus, entering settings and retrieving data from the relay. 11 buttons are provided for navigation around the menu structure.

4.1 LEDs












LED Categories			LED Status		
Name	describe	Color	ON	OFF	Flashing
Run	equipment running	Green	crash	crash	Working properly
DT	communication	Green	No communication	No communication	Normal communication
ALM	alarm	Yellow	Device failure or protection alarm	Running normally	---
ON	closed position	Red	Switch is on	Switch is not on	---
OFF	Opened position	Green	Switch is off	Switch is not off	---
ACT	action	Red	Protective action	No protective action	---
79	reclose	Red	Reclose export	Normal	---
OC	Over current	Red	Over current action	Normal	---
SEF	Ground fault	Red	Ground fault action	Normal	---
86	lockout	Red	Reclosing lockout alarm	Normal	---

4.2 Keypad

The main keys




User actions are mainly concentrated on the operation panel.



Key	Function
	Increase the number
	Reduce the number
	Move up or page up
	Move down or page down
	Move left
	Move right
	Return to the superior or Cancel the operation
	Enter the menu of confirm the operation

When you press the button, the buzzer of device will sing make a sound, so that the operation is valid; if not, please do it again.

Operation buttons

Key	Function
	Touch reset button, you can reset protect information
	Touch closing button, close switch
	Touch tripping button, trip switch

When you press the button, the buzzer of device will make a sound, so that the operation is valid; if not, please do it again.


Note: When you press the closing-button or tripping-button, you must make sure the device is unlock; if the lockout-light is on, please press the reset-button to reset the device, so that you can close or trip the switch.

4.3 LCD

A 4 line by 16 character liquid crystal display with power save operation indicates the relay identifier, settings, instrumentation, fault data and control commands.

4.4 The Main Menu














Press "Enter" when on the main screen, as shown below, including "EDIT" and "VIEW" menu item. Select the corresponding menu item with the [←] key, [→] and press "Enter" button to enter the corresponding sub-menu, press the "ESC" key to return to the previous screen.



4.5 Submenu










Edit submenu

Choose the edit options, the screen will enter the submenu of the Edit menu, as shown below, the submenu includes "Relay", "Para", "Chnl", "Clr", "Time", "Comm", "Fac", "Test".

 Relay	   Clr. Time Comm	  Fac. Test
Submenu of edit		
 Relay	Enter "Relay" submenu, you can modify the protection feature.	
 Para	Enter "Para" submenu, you can modify or view other parameters. Like communication address, baud rate, password, trip and close pulse time.	
 Adj.	Enter "Adj." submenu, current and voltage values can be corrected, press the function key "Enter" to be modified.	
 Clr.	Enter "Clr." submenu, you can clear out the trip report, the alarm report, the SOE report, the count report and all report.	
 Time	Enter the "Time" submenu will modify or check the time.	
 Comm	Enter "Comm" Sub-menu, choose the way to communication, it include "GSM"and "GPRS".	
 Fac.	Enter "Fac." Sub-menu, modify and view the factory settings.	


View submenu

Choose the view options, the screen will enter the submenu of the View menu, as shown below, the sub-menu includes "Meter", "RPT", "Relay", "Input", "Ver".

 Meter	 Rpt	 Relay	 Input	 Ver
View submenu				
 Meter	Enter "Meter" submenu, you can view the primary side measurement data include: PT voltage, phase current, zero sequence current, frequency, phase angle.			
 Rpt	Enter "RPT" submenu, you can view trip report, alarm report, SOE report, count report.			
 Relay	Enter "Relay" submenu, you can view each protection feature is invested and set up the parameters			
 Input	Enter the "Input" submenu, you can view the input signal. The input signal includes: Breaker close, Prepaid open, Prepaid close, Spring ready.			
 Ver	Enter "Ver" submenu, you can view the product model, serial number and date of manufacture.			

4.6 Entering the password interface

According to the above operation, before entering each item will first enter a password input interface to prevent professional staff misuse. The device original password is "0099", as shown below, press [←] and [→] keys to switch, press the [+] and [-] keys to increase and decrease the number of line with the correct password press "Enter" button to enter.




4.7 Relay setting

Select the "Relay" in the Edit submenu item, press the function key "Enter" to enter the password screen, enter the correct password to enter the "Relay" submenu, as Shown below, each item has a checkbox and set values.

Ph.OC1:	X		1. Ph.OC1: instantaneous overcurrent Protection
Ph.OC2:	X		2. Ph.OC2: definite time overcurrent protection
Ph.OC3:	X		3. Ph.OC3: overcurrent protection
SEF:	X		4. SEF: sensitive earth fault protection
Cold load:	X		5. Cold Load: cold load pickup
Reclose:	X		6. Reclose: OC reclose
Recl .ACC:	X		7. Recl.ACC: reclosing acceleration protection
Manu.ACC:	X		8. Manu.ACC: manual closing acceleration protection
Ph.OV:	X		9. PH.OV: overvoltage protection
Ph.UV:	X		10. PH.UV: low voltage protection
Power on:	X		11. Power on: power on protection
Prepaid:	X		12. Prepaid: debt protection
Power Alm:	X		23. Power Alm: stored energy alarm


Three sections phase overcurrent

Select Ph.OC menu  option press "Enter" key to enter, operational processes as shown below:

<div>Ph.OC1 (1/2) Pickup current: 0600.0 A Scp:00.1 -6000.0</div> <div>↓</div> <div>Ph.OC1 (2/2) Delay time: 0.00 S Scp:0.00-9.99</div>	<p>Step 1: Setting the overcurrent protection current value, the current value can be between 0.1A ~ 6000A.</p> <p>Step 2: Setting the overcurrent delay time, the delay time can be between 0S ~ 9.99S.</p> <p>Note: Press [↓] key to switch to next screen, press the [+] and [-] keys to switch the modified current value and delayed time.</p>
The operational processes of simple overcurrent protection setting	

Note: Here are three-stage overcurrent protection, the use of the other two are the same.

Sensitive earth fault

Select SEF menu  option press "Enter" key to enter, operational processes as shown below:

<div>SEF(1/5) Operating mode: 2 Scp:1 -4</div> <div>↓</div> <div>SEF(2/5) Pickup current: 120.0 A Scp:00.1 - 999.9</div> <div>↓</div> <div>SEF(3/5) Delay time: 000.2 S</div> <div>↓</div> <div>SEF(4/5) Start angle: 240 Scp:000 - 360</div> <div>↓</div> <div>SEF(5/5) End angle: 300 Scp:000 - 360</div>	<p>Step 1: Choose the SEF operating mode (1: Alarm 2: Trip 3: Direction alarm 4: Direction trip).</p> <p>Step 2: Setting the SEF protection current value, the SEF current value can be between 0.1A ~ 999.9A.</p> <p>Step 3: Setting the SEF delay time, the delay time can be between 0 ~ 600.0S/M.</p> <p>Step 4: Setting the SEF start angle, the angle can be between 0 ~ 360.</p> <p>Step 5: Setting the SEF end angle, the angle can be between 0 ~ 360.</p> <p>Note: 1.Press [↓] key to switch to next screen, press the [+] and [-] keys to switch the modified current value and delayed time. 2. Step 4 and step 5 only need to be set when zero sequence direction overcurrent is required.</p>
The operational processes of SEF protection setting	

Cold Load

Select Cold Load menu  option press "Enter" key to enter, operational processes as shown below:

<div>Cold load (1/2) Pickup current: 1000.0 A Scp:01.0 -6000.0</div> <div>Cold load (2/2) Delay time: 02.00 S Scp:0.00-99.99</div>	<p>Step 1: Setting the cold load protection current value, the current value can be between 1A ~ 6000A.</p> <p>Step 2: Setting the cold load delay time, the delay time can be between 0S ~ 99.99S.</p> <p>Note: Press [↓] key to switch to next screen, press the [+] and [-] keys to modified current value and delayed time.</p>
The operational processes of cold load protection setting	

Automatic reclosing (Reclose)

Select Reclose menu  option press "Enter" key to enter, operational processes as shown below:

<div>Reclose(1/6) Reclose count: 3 Scp:1 -4</div> <div>Reclose (2/6) 1st delay time: 08.00 S Scp:0.00-99.99</div> <div>Reclose (3/6) 2nd delay time: 08.00 S Scp:0.00-99.99</div> <div>Reclose (4/6) 3rd delay time: 08.00 S Scp:0.00-99.99</div> <div>Reclose (5/6) 4th delay time: 08.00 S Scp:0.00-99.99</div> <div>Reclose (6/6) Reset time: 080.0 S Scp:01.0-180.0</div>	<p>Step 1: Choose the automatic reclosing times (1: One, 2: Two, 3: Three, 4: Four).</p> <p>Step 2: Setting the 1st delay time, the delay time can be between 0S ~ 99.99S.</p> <p>Step 3: Setting the 2nd delay time, the delay time can be between 0S ~ 99.99S.</p> <p>Step 4: Setting the 3rd delay time, the delay time can be between 0S ~ 99.99S.</p> <p>Step 5: Setting the 4th delay time, the delay time can be between 0S ~ 99.99S.</p> <p>Step 6: Setting the automatic reclosing reset time, the reset time can be between 1.2S~ 180.0S.</p> <p>Note: Press [↓] key to switch to next screen, press the [+] and [-] keys to switch the mode and modified delayed time/reset time.</p>
The operational processes of automatic reclosing setting	

Reclosing acceleration (Recl.ACC)

Select Recl.ACC menu  option press "Enter" key to enter, operational processes as shown below:

<div>Recl.ACC (1/2)</div> <div>Pickup current:</div> <div>0500.0 A</div> <div>Scp:00.1 -6000.0</div> <div>↓</div> <div>Recl.ACC (2/2)</div> <div>Delay time:</div> <div>0.00 S</div> <div>Scp:0.00-9.99</div>	<p>Step 1: Setting the reclosing acceleration protection current value, the current value can be between 0.1A ~ 6000A.</p> <p>Step 2: Setting the delay time, the delay time can be between 0S ~ 9.99S.</p> <p>Note: Press [↓] key to switch to next screen, press the [+] and [-] keys to switch the modified current value and delayed time.</p>
The operational processes of reclosing acceleration protection setting	

Manual closing acceleration (Manu.ACC)

Select Manu.ACC menu  option press "Enter" key to enter, operational processes as shown below:

<div>Manu.ACC(3/3)</div> <div>Exit time:</div> <div>3.00 S</div> <div>Scp:0.10-9.99</div> <div>↓</div> <div>Manu.ACC(2/3)</div> <div>Pickup current:</div> <div>0500.0 A</div> <div>Scp:00.1 -6000.0</div> <div>↓</div> <div>Manu.ACC(3/3)</div> <div>Delay time:</div> <div>0.00 S</div> <div>Scp:0.00-9.99</div>	<p>Step 1: Setting the manual closing acceleration exit time, the exit time can be between 0.1S ~ 9.99S.</p> <p>Step 2: Setting the manual closing acceleration protection current value, the current value can be between 0.1A ~ 6000A.</p> <p>Step 3: Setting the delay time, the delay time can be between 0S ~ 9.99S.</p> <p>Note: Press [↓] key to switch to next screen, press the [+] and [-] keys to switch the modified current value and delayed time.</p>
The operational processes of manual closing acceleration protection setting	

Over voltage protection (Ph.OV)

Select PH.OV menu  option press "Enter" key to enter, operational processes as shown below:


<div>Ph.OV (1/2) Pickup voltage: 12.00 KV Scp:0.01 -42.00</div> <div>↓</div> <div>Ph.OV (2/2) Delay time: 00.00 S Scp:0.00-99.99</div>	<p>Step 1: Setting the overvoltage protection voltage value, the voltage value can be between 0.01KV ~ 42.0KV.</p> <p>Step 2: Setting the delay time, the delay time can be between 0S ~ 99.99S.</p> <p>Note: Press [↓] key to switch to next screen, press the [+] and [-] keys to switch the modified voltage value and delayed time.</p>
The operational processes of overvoltage protection setting	



Low-voltage protection (Ph.UV)

Select PH.UV menu  option press "Enter" key to enter, operational processes as shown below:

<div>Ph.UV (1/3) Operating mode: 1 Scp:1 -2</div> <div>↓</div> <div>Ph.UV (2/3) Pickup voltage: 06.00 KV Scp:0.01 -42.00</div> <div>↓</div> <div>Ph.UV (3/3) Delay time: 00.00 S Scp:0.00-99.99</div>	<p>Step 1: Choose the low voltage protection operating mode (1: Trip 2: Alarm).</p> <p>Step 2: Setting the low voltage protection voltage value, the voltage value can be between 0.01KV ~ 42.0KV.</p> <p>Step 2: Setting the delay time, the delay time can be between 0S ~ 99.99S.</p> <p>Note: Press [↓] key to switch to next screen, press the [+] and [-] keys to switch the modified voltage value and delayed time.</p>
The operational processes of low voltage protection setting	


Power on

Select Power on menu  option press "Enter" key to enter, operational processes as shown below:

	<p>Step 1: Setting the Power on protection voltage value, the voltage value can be between 0.01KV ~ 42.0KV.</p> <p>Step 2: Setting the delay time, the delay time can be between 0S ~ 99.99S.</p> <p>Note: Press [↓] key to switch to next screen, press the [+] and [-] keys to switch the modified voltage value and delayed time.</p>
	
The operational processes of Power on protection setting	

Prepaid (Optional features)

Select Prepaid menu  option press "Enter" key to enter, operational processes as shown below:

	<p>Step 1: Setting the delay time, the delay time can be between 0S ~ 99.99S.</p> <p>Note: Press the [+] and [-] keys to switch the delayed time.</p>
The operational processes of prepaid protection setting	

4.8 Save parameter

After setting, press "ESC" key to exit, if modified below figure will show. If you need to save press "Enter" key and input password, otherwise press "ESC" key.


--

4.9 Parameter set

Press the EDIT → Para, enter the "parameter set". Press the [+] and [-] keys to modified parameter value.

CT, CT0 rate set

<div>Parameter set CT rate 600/5 Scp: 001/1 -999/5</div>	CT rate is the three phase current rate. The value of CT ratio is equal to the primary side current value divided by the secondary side current value.
<div>Parameter set CT0 rate 020/1 Scp: 001/1 -999/5</div>	CT0 rate is the real zero sequence current rate. The value of CT0 ratio is equal to the primary side current value divided by the secondary side current value.
<div>Parameter set PT rate 045 Scp: 001 -999</div>	PT rate is the power voltage rate. The value of PT ratio is equal to the primary side voltage value divided by the secondary side voltage value.

Note:

- 1 Different current transformer, CT ratio becomes different.
- 2 Different current transformer, CT0 ratio becomes different.
- 3 Different PT power voltage transformer, PT ratio becomes different.

Wiring mode set

<div>Parameter set CT Numbe thr.</div>	<p>Phase current wiring mode.</p> <p>Thr.: Three-phase</p> <p>Two: Two-phase</p>
<div>Parameter set Zero-cur Comp</div>	<p>zero sequence current wiring mode.</p> <p>Comp: Synthetic zero sequence</p> <p>Real: Real mining zero sequence</p>

Note: The wiring mode must be the same as that of the circuit breaker.

Close and trip pulse time set

<div>Parameter set</div> <div>Close pulse time</div> <div>050 mS</div> <div>Scp: 010 -999</div>	<div>Parameter set</div> <div>Trip pulse time</div> <div>040 mS</div> <div>Scp: 010 -999</div>
---	--

"Close pulse time" is the discharge time for close coil. "Trip pulse time" is the discharge time for trip coil.

Note: Please do not modify the trip and close pulse time.

Password set

<div>Parameter set</div> <div>Operate password</div> <div>0099</div> <div>Scp: 0000 -9999</div>	<p>The device initial password is "0099", the password for the user to modify from the "0000" ~ "9999", when revised press "Enter" key to confirm, enter the password before the modification.</p>
---	--

Set the communication parameter

Name	Setting range	Step length	Description
Comm1 Status	0~1	1	0: Close this channel 1: Open this channel
Comm1 Baud	0~38400	1	Default 9600
Comm1 Protocol	1~4	1	1: IEC60870-5-101 2: IEC60870-5-104 3: DNP3.0 4: MODBUS
Comm1 Balance	0~1	1	0: Unbalanced 1: Balance
Comm1 Address	1~65535	1	Source address
Comm1 Report	0~65535	1	Destination address
Comm1 Upload	0~1	1	0: Do not upload actively 1: Active upload
Comm2 Status	0~1	1	0: Close this channel 1: Open this channel
Comm2 Baud	0~38400	1	Default 9600
Comm2 Protocol	1~4	1	1: IEC60870-5-101 2: IEC60870-5-104 3: DNP3.0 4: MODBUS
Comm2 Balance	0~1	1	0: Unbalanced 1: Balance
Comm2 Address	1~65535	1	Source address
Comm2 Report	0~65535	1	Destination address
Comm2 Upload	0~1	1	0: Do not upload actively 1: Active upload

Signal type	1~2	1	1: Single point 2: Double point
Control type	1~2	1	1: Single point 2: Double point
Meter type	1~4	1	1: Normalized telemetry 2: Normalized telemetry without quality 3: Standardized telemetry 4: Short floating point telemetry
Address len	1~2	1	Address length 1: 1 byte 2: 2 byte
COT len	1~2	1	COT length 1: 1 byte 2: 2 byte
I factor	0.01~100	0.01	Phase current multiplier
I deadband	0.1~1000	0.1	Phase current dead zone
I0 factor	0.01~100	0.01	Zero sequence current multiplier
I0 deadband	0.1~1000	0.1	Zero sequence current dead zone
U factor	0.01~100	0.01	Line voltage multiplier
U deadband	0.1~1000	0.1	Line voltage dead zone
U0 factor	0.01~100	0.01	Zero sequence voltage multiplier
U0 deadband	0.1~1000	0.1	Zero sequence voltage dead zone
P factor	0.01~100	0.01	Power multiplier
P deadband	0.1~1000	0.1	Power dead zone
COS factor	0.01~100	0.01	COS multiplier
COS deadband	0.1~1000	0.1	COS dead zone
OTH factor	0.01~100	0.01	Other multiplier
OTH deadband	0.1~1000	0.1	Other dead zone
CLASSA	0~3	1	Class for analog event data
CLASSB	0~3	1	Class for digital event data
Select Timeout	0~30	0.1	Select/operate time-out
Confirm Link	0~1	1	Enable confirm data link
Link Retry Times	0~15	1	Data link retries times
Link Timeout	0~50	0.1	Seconds to data link time-out
Upload Confirm	0~1	1	Enable upload confirmation
Upload Timeout	0~50	0.1	Seconds to upload time-out
Upload Retry Times	2~10	1	Upload retries times
Auto Refresh	0~1	1	Enable automatic reset of events
Refresh time	0~65535	1	Seconds to automatic reset event

4.10 Calibration

Select the Edit submenu in "Adj.", press "Enter" key to enter into the password screen, enter the correct password to enter the "Adj." submenu, press the [+] and [-] keys to correct the value of current and voltage.

Note: All voltage and current values in the factory have been corrected before. Please do not change the parameter values.

4.11 Clear report

Select the Edit submenu in "Clr", press "Enter" key to enter, as shown below:

1.Clear trip 2.Clear alarm 3.Clear SOE 4.Clear count	Select "1": Clear the trip report.
5.Clear all	Select "2": Clear the alarm report.
	Select "3": Clear the SOE report.
	Select "4": Clear the count report.
	Select "5": Clear the all report (include trip record, alarm record, SOE record and count record) .

4.12 Factory setting

All the values in the factory have been corrected before. Please do not change the values.





4.13 View primacy meter

Enter the main menu select the "VIEW" option press "Enter" key to enter, and then select the "Meter" option to press "Enter" key to enter the "Primacy Meter" submenu, you can view all the primacy meter value.


PrimacyMeter Ia= 0.000A Ib= 0.000A Ic= 0.000A	1. Ia: Primary side current of phase a 2. Ib: Primary side current of phase b 3. Ic: Primary side current of phase c
PrimacyMeter 3I0= 0.000A UAB= 0.000KV UBC= 0.000KV	4. 3I0: Zero sequence primary current 5. UAB: Line voltage UAB primary side value 6. UBC: Line voltage UBC primary side value
PrimacyMeter F= 0.000 Hz P= 0.000 KW Q= 0.000 KVar	7. F: Frequency 8. P: Active power 9. Q: Reactive power
PrimacyMeter AP=0.000 KVA COS= 0.00 Iaang= 0.000	10. AP: Apparent power 11. COS: Power factor
PrimacyMeter Ibang= 0.000 Icang= 0.000 I0ang= 0.000	12. Iaang: Angle of phase a current 13. Ibang: Angle of phase b current 14. Icang: Angle of phase c current
PrimacyMeter Uaang= 0.000 Ubang= 0.000	15. I0ang: Angle of zero sequence current 16. Uaang: Angle of line voltage UAB 17. Ubang: Angle of line voltage UBC













4.14 View SOE

Enter the main menu select the "VIEW" option press "Enter" key to enter, and then select "RPT" option press "Enter" key to enter the "RPT" submenu, you can view the SOE record events, recording events include: trip signal, alarm signal, telemetry signal (circuit breaker status, whether the manual or remote operation, fault trip, time and date, etc.) and count signal (the count of trip).

 Trip	 Alm	 Sig	2013-11-07<092> 15:27:36.678 BC OC1 Trip I= 604.3A	2013-05-07<022> 10:27:36.678 Alm:trip fault	2013-10-05<098> 15:47:36.678 Breaker open 1→0
 Cnt.	OC= 4 SEF= 1 Manual= 10 Remote= 0	Other= 4 All= 19 Time= 52			

4.15 View relay and setting

Enter the main menu select the "VIEW" option press "Enter" key to enter, and then select the "Relay" option to press "Enter" key to enter the "Relay" submenu, you can view all the protection is enabled or disabled, select the  option press "Enter" key to enter the value you can view each protection, press the arrow keys to switch screens.

Ph.OC1:	X	
Ph.OC2:	X	
Ph.OC3:	X	
SEF:	X	
Cold load:	X	
Reclose:	X	
Recl .ACC:	X	
Manu.ACC:	X	
Ph.OV:	X	
Ph.UV:	X	
Power on:	X	
Prepaid:	X	
Power Alm:	X	

4.16 View input signal

Enter the main menu select the "VIEW" option press "Enter" key to enter, and then select the "Input" option press "Enter" key to enter the "Input" submenu, you can view the state of input signal.

Input show		Input show		Input show	
PrepaidC	0	PrepaidT	0	Remote	0
Close-	0	Bak	0	Bak	0
Spring-	0	Bak	0	Bak	0


4.17 View version information

Enter the main menu select the "VIEW" option press "Enter" key to enter, and then select the "Ver" option press "Enter" key to enter the "Ver" submenu, You can view the device type, version number, production date, and device ID.

Device type: RWC-4LC	Production date: 2013-01-01
Version: 2.5	Device ID: 01912-26601

Chapter 5: Installation and Maintenance

As show below, the installation mode is cabinet door imbedded. The wiring terminal wiring comes out of the backboard of the device.



Chapter 6: Decommission and Disposal

6.1 Decommission

Shut-down Power Supply

Shut-down Device Power Supply: Turn off external power supply switch of the device.

Disconnect All Power Cables

Disconnect all power cables connected to the device.

Danger: Before disconnecting all power cables connected to the device power module, it must confirm that the external power switch is turned off to avoid danger.

Danger: Disconnecting all power cables connected to the device alternating current module, it must confirm that the equipment corresponding to input alternating component has stopped operation to avoid danger.

Dismantle from Display Cabinet

When the above steps are completed, loosen the fix screws and dismantle the device from the display cabinet.


Danger: When neighboring equipment is in operation, it must strictly confirm the safety distance between the dismantled device and other device in operation and unskilled professional shall take particular caution.

6.2 Disposal

When dispose decommissioned device, please follow relevant regulations of the country where the product is used for the disposal of scrapped electronic products.


Caution: It must strictly adhere to relevant regulations of the country where the product is used for the disposal of scrapped electronic products.

Attachment1: Device Terminal Diagram




Attachment2: Device Typical wiring Diagram (line mode)


D1



D2



D4



D3

